

# Material Safety Data Sheet

## 1. PRODUCT AND COMPANY IDENTIFICATION

Product name: Helium

Chemical formula He

Synonyms: Helium, Helium gas, Gaseous helium, Balloon gas

Product Use Description: General Industrial

Company: SGS Gases Ltd

Telephone: 07522 234374

Emergency telephone number: 07522 234374

## 2. COMPOSITION/INFORMATION ON INGREDIENTS

Components CAS Number Concentration (Volume) Helium 7440-59-7 100 %

Concentration is nominal.

---

## 3. HAZARDS IDENTIFICATION

Emergency Overview

High pressure gas. Can cause rapid suffocation. Self contained breathing

apparatus (SCBA) may be required.

#### Potential Health Effects

Inhalation: In high concentrations may cause asphyxiation. Asphyxiation may bring about unconsciousness without warning and so rapidly that victim may be unable to protect themselves.

Eye contact: No adverse effect.

Skin contact: No adverse effect.

Ingestion: Ingestion is not considered a potential route of exposure.

Chronic Health Hazard: Not applicable.

#### Exposure Guidelines

Primary Routes of Entry: Inhalation

Target Organs: None known.

Symptoms: Exposure to oxygen deficient atmosphere may cause the following symptoms: Dizziness. Salivation. Nausea. Vomiting. Loss of mobility/consciousness.

Aggravated Medical Condition: None.

Environmental Effects: Not harmful.

---

#### 4. FIRST AID MEASURES

General advice: Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.

Eye contact: Not applicable.

↑

Skin contact: Not applicable.

Ingestion: Ingestion is not considered a potential route of exposure.

Inhalation: Remove to fresh air. If breathing has stopped or is labored, give assisted respirations. Supplemental oxygen may be indicated. If the heart has stopped, trained personnel should begin cardiopulmonary resuscitation immediately. In case of shortness of breath, give oxygen.

---

## 5. FIRE-FIGHTING MEASURES

6.

Suitable extinguishing media: All known extinguishing media can be used.

Specific hazards: Upon exposure to intense heat or flame, cylinder will vent rapidly and or rupture violently. Product is nonflammable and does not support combustion. Move away from container and cool with water from a protected position. Keep containers and surroundings cool with water spray.

Special protective equipment: Wear self contained breathing apparatus for fire fighting if necessary. for fire-fighters

---

## 7. ACCIDENTAL RELEASE MEASURES

Personal precautions: Evacuate personnel to safe areas. Wear self-contained breathing apparatus when entering area unless atmosphere is proved to be safe. Monitor oxygen level. Ventilate the area.

Environmental precautions: Do not discharge into any place where its accumulation could be dangerous. Prevent further leakage or spillage if safe to do so.

Methods for cleaning up: Ventilate the area.

Additional advice: If possible, stop flow of product. Increase ventilation to the release area and monitor oxygen level. If leak is from cylinder or cylinder valve, call the SGS Gases emergency telephone number. If the leak is in the user's system, close the cylinder valve, safely vent the pressure, and purge with an inert gas before attempting repairs.

---

## 8. HANDLING AND STORAGE

### Handling

Protect cylinders from physical damage; do not drag, roll, slide or drop. Do not allow storage area temperature to exceed 50°C (122°F). Only experienced and properly instructed persons should handle compressed gases. Before using the product, determine its identity by reading the label. Know and understand the properties and hazards of the product before use. When doubt exists as to the correct handling procedure for a particular gas, contact the supplier. Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.



When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against either a

wall or bench or placed in a container stand and is ready for use. Use an adjustable strap wrench to remove over-tight or rusted caps. Before connecting the container, check the complete gas system for suitability,

particularly for pressure rating and materials. Before connecting the container for use, ensure that back feed from the system into the container is prevented. Ensure the complete gas system is compatible for pressure rating and materials of construction. Ensure the complete gas system has been checked for leaks before use. Employ suitable pressure regulating devices on all containers when the gas is being emitted to systems with lower pressure rating than that of the container. Never insert an object (e.g. wrench, screwdriver, pry bar, etc.) into valve cap openings. Doing so may damage valve, causing a leak to occur. Open valve slowly. If user experiences any difficulty operating cylinder valve discontinue use and contact supplier.

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Close valve after each use and when empty. Replace outlet caps or plugs and container caps as soon as container is disconnected from equipment.

Do not subject containers to abnormal mechanical shocks which may cause damage to their valve or safety devices. Never attempt to lift a cylinder by its valve protection cap or guard. Do not use containers as rollers or supports or for any other purpose than to contain the gas as supplied.

Never strike an arc on a compressed gas cylinder or make a cylinder a part of an electrical circuit. Do not smoke while handling product or cylinders. Never re-compress a gas or a gas mixture without first consulting the supplier. Never attempt to transfer gases from one cylinder/container to another. Always use backflow protective device in piping. When returning cylinder install valve outlet cap or plug leak tight. Never use direct flame or electrical heating devices to raise the pressure of a container. Containers should not be subjected to temperatures above 50°C (122°F). Prolonged periods of cold temperature below -30°C (-20°F) should be avoided.

## Storage

Full containers should be stored so that oldest stock is used first. Stored containers should be periodically checked for general condition and leakage. Observe all regulations and local requirements regarding storage of containers. Protect containers stored in the open against rusting and extremes of weather. Containers should not be stored in conditions likely to encourage corrosion.

The container valves should be tightly closed and where appropriate valve outlets should be capped or plugged. Container valve guards or caps should be in place. Keep containers tightly closed in a cool, well-ventilated place. Store containers in location free from fire risk and away from sources of heat and ignition. Full and empty cylinders should be segregated. Do not allow storage temperature to exceed 50°C (122°F).

Return empty containers in a timely manner.



#### Technical measures/Precautions

Containers should be segregated in the storage area according to the various categories (e.g. flammable, toxic, etc.) and in accordance with local regulations. Keep away from combustible material.

---

### 9. EXPOSURE CONTROLS / PERSONAL PROTECTION

Engineering measures: Provide natural or mechanical ventilation to prevent oxygen deficient atmospheres below 19.5% oxygen.

#### Personal protective equipment

Respiratory protection: Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be used in oxygen-deficient atmosphere. Air purifying respirators will not provide protection. Users of breathing apparatus must be trained.

Hand protection: Sturdy work gloves are recommended for handling cylinders. The breakthrough time of the selected glove(s) must be greater than the intended use period.

Eye protection: Safety glasses recommended when handling cylinders.

Skin and body protection: Safety shoes are recommended when handling cylinders.

Special instructions for protection and hygiene: Ensure adequate ventilation, especially in confined areas.

Remarks: Simple asphyxiant.

---

## 10. PHYSICAL AND CHEMICAL PROPERTIES

Form: Compressed gas.

Colour: Colourless gas

Odour: No odour warning properties.

Molecular Weight: 4 g/mol

Relative vapour density: 0.138 (air = 1)

Density: 0.012 lb/ft<sup>3</sup> (0.0002 g/cm<sup>3</sup>) at 70 °F (21 °C)

Note: (as vapour)

Specific Volume: 96.68 ft<sup>3</sup>/lb (6.0349 m<sup>3</sup>/kg) at 70 °F (21 °C)

Boiling point/range: -452 °F (-268.9 °C)

Critical temperature: -450 °F (-267.9 °C)

Water solubility: 0.0015 g/l

---

## 11. STABILITY AND REACTIVITY

Stability: Stable under normal conditions.

Hazardous decomposition: None.

## 12. TOXICOLOGICAL INFORMATION

### Acute Health Hazard

Ingestion: No data is available on the product itself.

↑

Inhalation: No data is available on the product itself.

Skin.: No data is available on the product itself.

---

## 13. ECOLOGICAL INFORMATION

### Ecotoxicity effects

Aquatic toxicity: No data is available on the product itself.

Toxicity to other organisms: No data available.

### Persistence and degradability

Mobility: No data available.

Bioaccumulation: No data is available on the product itself.

### Further information

This product has no known eco-toxicological effects.

---

## 14. DISPOSAL CONSIDERATIONS



Waste from residues / unused: Contact supplier if guidance is required.  
Return unused product in original products cylinder to supplier.

Contaminated packaging: Return cylinder to supplier.

---

## 15. TRANSPORT INFORMATION

CFR

Proper shipping name: Helium, compressed

Class: 2.2

UN/ID No.: UN1046

IATA

Proper shipping name: Helium, compressed

Class: 2.2

UN/ID No.: UN1046

IMDG

Proper shipping name: HELIUM, COMPRESSED

Class: 2.2

UN/ID No.: UN1046

CTC

Proper shipping name: HELIUM, COMPRESSED

Class: 2.2

UN/ID No.: UN1046

Further Information

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.

## 16. REGULATORY INFORMATION

OSHA Hazard Communication Standard (29 CFR 1910.1200) Hazard Class(es)  
Compressed Gas.



Country Regulatory list Notification

USA TSCA Included on Inventory.

EU EINECS Included on Inventory.

Canada DSL Included on Inventory.

Australia AICS Included on Inventory.

Japan ENCS Included on Inventory.

South Korea ECL Included on Inventory.

China SEPA Included on Inventory.

Philippines PICCS Included on Inventory.

EPA SARA Title III Section 312 (40 CFR 370) Hazard Classification:

Sudden Release of Pressure Hazard.

US. California Safe Drinking Water & Toxic Enforcement Act (Proposition 65)

This product does not contain any chemicals known to State of California to cause cancer, birth defects or any other harm.

---

## 17. OTHER INFORMATION

NFPA Rating: 0

Health: 0

Fire: 0

Instability: 0

Special: SA

HMIS Rating

Health: 0

Flammability: 0

Physical hazard: 3

Prepared by : SGS Gases Ltd

[www.sgsgases.co.uk](http://www.sgsgases.co.uk)

